

**ADDENDUM 2
TO THE CONTRACT PROVISIONS AND CONTRACT PLANS**


FOR

**CITY OF WOODLAND
WATER TREATMENT PLANT HVAC AND ELECTRICAL IMPROVEMENTS**

G&O #16238

ISSUED THIS DATE: MONDAY, AUGUST 20, 2018

**BID OPENING: 1:00 P.M. (LOCAL TIME) ON
TUESDAY, AUGUST 21, 2018
CITY OF WOODLAND
230 DAVIDSON AVENUE
WASHINGTON, 98674**



Bidder shall acknowledge receipt of this Addendum on Page P-4 of the Proposal.

TO PROSPECTIVE BIDDERS:

The attention of all prospective bidders on the above project is directed to the following additions and modifications to the Contract Provisions and Contract Plans.

I. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE TECHNICAL SPECIFICATIONS

ITEM NO. 1:

Page 15050-3R, Specification Section 15050-2.3 – Miscellaneous Fittings

ADD the following after subsection A:

“B. FLANGED COUPLING ADAPTERS

Flanged coupling adapters shall be Rockwell (Smith-Blair) Type 912 Dresser Style 127 or equal.”