

**ADDENDUM NO. 2
TO THE CONTRACT PROVISIONS AND CONTRACT PLANS**

FOR

**CITY OF QUINCY
NEUTRALIZED BRINE WASTE CONVEYANCE SYSTEM**

G&O #18030

ISSUED THIS DATE: MONDAY, DECEMBER 10, 2018

**BID OPENING: 10:00 AM (LOCAL TIME) ON
WEDNESDAY, DECEMBER 12, 2018
CITY OF QUINCY
POLICE DEPARTMENT BUILDING
223 FIRST AVENUE SW
QUINCY, WASHINGTON 98848**



Bidder shall acknowledge receipt of this Addendum on Page P-5 of the Proposal.

TO PROSPECTIVE BIDDERS:

The attention of all prospective bidders on the above project is directed to the following additions and modifications to the Contract Provisions and Contract Plans.

I. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE PROPOSAL

ITEM NO. 1:

Page P-2, Proposal

On Bid Item No. 13, Gate Valve, 4-Inch Diameter, **DELETE** the quantity "2 EA" and **REPLACE** with the following:

"4 EA"

II. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE SPECIAL PROVISIONS

ITEM NO. 1:

Page 1-28, Special Provisions Section 1-05.14, Cooperation With Other Contractors

ADD the following after Section 1-05.13:

“1-05.14 Cooperation With Other Contractors

(March 13, 1995)

This Section is supplemented with the following:

Other Contracts or Other Work

It is anticipated that the following work adjacent to or within the limits of this project will be performed by others during the course of this project and will require coordination of the work:

The Contracting Agency will be constructing a water well and reservoir south of “D” Street NW in the vicinity of STA 44+00.

The Contracting Agency will be constructing miscellaneous improvements at its Primary Industrial Wastewater Treatment Facility at the southeast corner of “B” Street SW and 13th Avenue SW.

The Contracting Agency will be constructing a Roundabout at the intersection of SR 28 and 13th Avenue SW.

The Microsoft Corporation will be constructing a new Data Center west of 13th Avenue NW, east of County Road “S” NW, and north of the BNSF railroad tracks.

The owner of the private property adjacent to the north side of Port Industrial Parkway (Grant County Port District No. 1) will be constructing parking lot improvements in the vicinity of STA 37+00.

The owner of the private property adjacent to the south side of Port Industrial Parkway (Quincy Fresh Fruit Land Holdings, LLC) will be constructing building improvements between STA 29+18 and STA 35+70.

The Contractor shall coordinate the work in the vicinity of these other operations at no additional cost to the Contracting Agency.”

ITEM NO. 2:

Page 8-9, Special Provisions Order of Work

DELETE the second paragraph.

III. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE CONTRACT PLANS

ITEM NO. 1:

SHEET 16, MISCELLANEOUS DETAILS

On the USBR Crossing Detail 1, **DELETE** Note No. 6 and **REPLACE** it with the following:

“The Contracting Agency will shut off flow to the existing 10” PVC C900 pipe prior to the Contractor constructing the proposed 6” HDPE NBW pipe. At the Contractor’s option, they may drain the 10” pipe in order to construct the 6” pipe as long as it is at no additional cost to the Contracting Agency.”