

**ADDENDUM 5  
TO THE CONTRACT PROVISIONS AND CONTRACT PLANS**

**FOR**

**CITY OF LONG BEACH  
REGIONAL BIOSOLIDS FACILITY**

**G&O #18522**

**ISSUED THIS DATE: FRIDAY, APRIL 5, 2019**

**BID OPENING: 2:00 PM (LOCAL TIME) ON  
TUESDAY, APRIL 9, 2019  
CITY OF LONG BEACH  
115 BOLSTAD AVENUE WEST  
LONG BEACH, WASHINGTON 98631**



**Bidder shall acknowledge receipt of this Addendum on Page P-4 of the Proposal.**

---

TO PROSPECTIVE BIDDERS:

The attention of all prospective bidders on the above project is directed to the following additions and modifications to the Contract Provisions and Contract Plans.

**I. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE  
TECHNICAL SPECIFICATIONS**

**ITEM 1:**

Page 13122-8, Specification Section 13122-2.3 B., SECONDARY FRAMING MEMBERS

**REVISE** the last paragraph as shown below (added text is italicized, deleted text is shown as strike out):

“Clean secondary framing components to be free from oil, dirt, loose scale and foreign matter; and apply *field touch up of galvanized surfaces in accordance with Specification Section 09900 “Painting”* ~~one coat of manufacturer’s standard primer to all non-galvanized components.~~”

**ITEM 2:**

Page 08360-2, Specification Section 08360-2.2, MATERIALS

**ADD** the following to the end of the first paragraph:

“Note, the 20-gauge, ribbed C-20 Series sectional steel service door, or other equivalent doors that meet the requirements of the building code and the design wind load for the project location and exposure, are also acceptable for use on this project.”

**II. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE CONTRACT PLANS**

**ITEM 1:**

**SHEET G-8 R, YARD PIPING PLAN - NORTH**

**ADD** the following sentence to Note 12:

“CATCH BASIN SHALL BE EQUIPPED WITH SOLID COVER.”

**ITEM 2:**

**SHEET G-9 R, YARD PIPING PLAN - SOUTH**

**CHANGE** the number of Note 12 from “12” to “11”

**ADD** the following sentence to Note 11:

“CATCH BASIN SHALL BE EQUIPPED WITH SOLID COVER.”

**ITEM 3:**

**SHEET A9-1, WOOD CHIP BUILDING ARCHITECTURAL NOTES AND SCHEDULES**

**ADD** the following note to the ROOM MATERIAL AND FINISH SCHEDULE:

“NOTE:

INTERIOR EXPOSED STRUCTURAL STEEL SHALL BE PAINTED PER SPECIFICATION SECTION 09900. (THE FACTORY FINISH NOTED IN THE FINISH SCHEDULE APPLIES TO THE INTERIOR SIDE OF THE METAL WALL AND ROOF PANELS.)”

**ITEM 4:**

**SHEET A10-1, SOLIDS HANDLING BUILDING ARCHITECTURAL NOTES AND SCHEDULES**

On the CEILING FINISH part of the ROOM MATERIAL AND FINISH SCHEDULE, **DELETE** the Finish “N/A” and **REPLACE** with the following for each room:

“PTS”

**ITEM 5:**

**SHEET A12-1, CURING AND SCREENING BUILDING ARCHITECTURAL NOTES AND SCHEDULES**

**ADD** the following note to the ROOM MATERIAL AND FINISH SCHEDULE:

**“NOTE:**

INTERIOR EXPOSED STRUCTURAL STEEL SHALL BE PAINTED PER SPECIFICATION SECTION 09900. (THE FACTORY FINISH NOTED IN THE FINISH SCHEDULE APPLIES TO THE INTERIOR SIDE OF THE METAL WALL AND ROOF PANELS.)”

**ITEM 6:**

**SHEET A13-1, FINISHED COMPOST STORAGE BUILDING ARCHITECTURAL NOTES**

**ADD** the following note to the ROOM MATERIAL AND FINISH SCHEDULE:

**“NOTE:**

INTERIOR EXPOSED STRUCTURAL STEEL SHALL BE PAINTED PER SPECIFICATION SECTION 09900. (THE FACTORY FINISH NOTED IN THE FINISH SCHEDULE APPLIES TO THE INTERIOR SIDE OF THE METAL WALL AND ROOF PANELS.)”