

**ADDENDUM 1
TO THE CONTRACT PROVISIONS AND CONTRACT PLANS**

FOR

**CITY OF GRANITE FALLS
WWTP DRAIN LIFT STATION REPLACEMENT**

G&O #21635.00



ISSUED THIS DATE: MONDAY, JULY 11, 2022

**REVISED BID SUBMITTAL: 11:30 AM (LOCAL TIME) ON
THURSDAY, JULY 14, 2022
CITY OF GRANITE FALLS
215 SOUTH GRANITE AVENUE
GRANITE FALLS, WASHINGTON 98252**

Bidder shall acknowledge receipt of this Addendum on Page P-4 of the Proposal.

TO PROSPECTIVE BIDDERS:

The attention of all prospective bidders on the above project is directed to the following additions and modifications to the Contract Provisions and Contract Plans.

I. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE CALL FOR BIDS

ITEM 1:

Page CB-1, Call for Bids

REVISE the first paragraph as shown below (added text is italicized, deleted text is shown as strike out):

“Sealed Proposals will be received by the undersigned at the City of Granite Falls, 215, South Granite Avenue, Granite Falls, Washington 98252, up to ~~11:00 a.m.~~ *11:30 a.m.*; local time on ~~Tuesday, July 12, 2022~~ *Thursday, July 14, 2022*, for furnishing the necessary labor, materials, equipment, tools, and guarantees thereof to construct WWTP Drain Lift Station Replacement.”

II. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE PROPOSAL

ITEM 1:

Page P-2, Proposal

Under the Unit Price and Amount columns on Bid Item 2, Minor Change, **DELETE** the “\$ _____” and **REPLACE** with the following:

“\$10,000”

II. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE TECHNICAL SPECIFICATIONS

ITEM 1:

Page 01110-3, Specification Section 01110-1.2, PROJECT INFORMATION

ADD the following paragraph after the last paragraph:

“Due to long lead times for some items of materials and equipment, it is anticipated that there will be a suspension or suspensions of the work and associated contract time during construction. The Contractor may request a suspension of contract time at any time after submittals for long-lead time items have been approved. The suspension will be granted provided that documentation is submitted showing that long-lead time materials have been ordered. No on-site work may be completed during suspension of contract time. If a suspension is requested and granted after on-site work has commenced, the Contractor shall secure the uncompleted work so that it is not damaged during the suspension and shall clean up the site so that it is useable by the Owner during the suspension. Any suspension of contract time will be at no additional cost to the Owner.”

III. ADDITIONS, MODIFICATIONS, AND/OR DELETIONS TO THE CONTRACT PLANS

ITEM 1:

SHEET S-3, CANOPY FOUNDATION PLAN, ROOF FRAMING PLAN, SECTION AND DETAILS

On Section D, **ADD** the following note below the detail:

“NOTE:

1. THE INTENT IS FOR ALL WELDS TO BE INSTALLED IN THE SHOP PRIOR TO HOT DIP GALVANIZING. AT CONTRACTOR’S OPTION, A BOLTED BEAM TO COLUMN CONNECTION OF CAPACITY EQUAL TO OR GREATER THAN THE WELDED CONNECTION SHOWN MAY BE PROPOSED IF NECESSARY FOR HOT DIP GALVANIZING.”